

**Shalfleet Village Hall -**  
**Maintenance Report.**  
**for SHS meeting on 13th January 2023.**

**Repairs.**

The gas boiler had its annual inspection and service in November. It required a replacement gas valve to retain its safety certificate.

**Improvements.**

**Other.**

Michael.

7th January 2023